

---


# The SB100 Pathways Project: Reaching a Net Zero Carbon Grid in California

SCCS Affiliates Meeting  
November 5<sup>th</sup>, 2020

**EJ Baik, Sally M. Benson**

Department of Energy Resources Engineering, Stanford University

In collaboration with Jane Long (EDF), Steven Hamburg (EDF), Armond Cohen (CATF), Clea Kolster (E3), Kiran Chawla (E3), Arne Olsen (E3), Jesse Jenkins (Princeton), Michael Colvin (EDF), David Victor (UCSD), and Rob Jackson (Stanford)




## Key Takeaways

---


- **SB100 Pathways Project (Long et al. 2020, *in review*)**
  - Reaching a net zero carbon grid in 2045 in California can be done cost-effectively if we develop ~30 GW of Clean Firm Resources
- **An Action Plan for Carbon Capture and Storage in California: Opportunities, Challenges, and Solutions (EFI and Stanford University, 2020)**
  - Utilizing NGCC-CCS in the electricity grid as early as 2030 to meet emissions reductions goals is cost-effective and puts California on path to meet its 2045 goals

# Executive Order (B-55-18) commits California to a carbon-neutral economy by 2045





# Decarbonizing the electricity grid and electrifying other end-uses of energy has significant implications





One of California's key climate policy is Senate Bill 100


# SB 100

2030 60% Renewable  
Portfolio Standard  
(RPS)


2045 Zero-Carbon Grid




California currently gets over 30% of its electricity from natural gas



California's Generation Mix



Source: CEC, 2019



---


# 2045

The **SB100 Pathways Project** utilized three independent capacity expansion and dispatch models to assess several different pathways of reaching a net zero carbon grid in California to meet its SB100 and carbon neutrality goals in 2045.




# Three distinct capacity expansion and dispatch models were used for The SB100 Pathways Project

Capacity expansion and dispatch models find the cost-optimal grid subject to meeting future annual load and policy goals (cost-optimal indicates minimizing both the capital cost of building new resources and annual operating costs)





# Three distinct capacity expansion and dispatch models were used for The SB100 Pathways Project





	<b>E3 RESOLVE</b>	<b>Stanford urbs</b>	<b>Princeton GenX</b>
<b>Spatial Resolution</b>	3 zones: CA, SW, NW	10 CA zones; 2 out of state zones	2 CA zones; 7 out of state WECC zones
<b>Zones Optimized</b>	California	California	WECC-wide
<b>Temporal Resolution</b>	37 representative days	1 year in hourly time steps (8760)	16 representative weeks with hourly resolution time steps (2,688 hours)




Technologies considered in the analysis include:

- Solar (Re)
  - Onshore Wind (Re)
  - Offshore Wind (Re)
  - Energy Storage (B)
  - Nuclear Power (N)
  - Natural Gas with Carbon Capture and Storage (C)
  - Zero Carbon Fuel (F)
- Renewable Resources
- Clean Firm Resources


With the development of clean firm resources, California can build a net zero carbon grid at approximately historic generation and transmission rates



With the development of clean firm resources, California can build a net zero carbon grid at approximately historic generation and transmission rates




With the development of clean firm resources, California can build a net zero carbon grid at approximately historic generation and transmission rates






Without clean firm resources, California's PV capacity will have to grow at unprecedented rates and reach more than double the PV build in the scenarios with clean firm resources






# So how much clean firm resources do we need? – approximately 30 GW



\*Dotted boxes indicate imported firm capacity



# Developing ~30 GW by 2045 will require action before 2030





---

# 2030

**An Action Plan for Carbon Capture and Storage in California: Opportunities, Challenges, and Solutions (EFI and Stanford University, 2020)**

We assess the role of NGCC-CCS in California's grid in 2030 in meeting California's climate goals



One of California's key climate policy is Senate Bill 100

# SB 100

2030 60% Renewable  
Portfolio Standard  
(RPS)


2045 Zero-Carbon Grid



In addition to meeting the RPS, cost-effective decarbonization of the economy will need meeting emissions reduction goals for the electricity sector in 2030 as well



**Figure 6: California Greenhouse Gas Emissions by Sector in the High Electrification Scenario**



Source: E3, 2018

Given climate goals for 2030, what does an optimized California grid look like?




Meeting California's 2030 RPS and emissions reduction goals for the electricity sector with NGCC-CCS in the system saves ~\$750 Million/year relative to a scenario without NGCC-CCS




FIGURE 3-6

**CAPACITY OF CALIFORNIA'S ELECTRICITY SYSTEM IN 2030 WITH AND WITHOUT CCS**







A decrease in natural gas generation relative to 2018 is made up largely with more PV generation




# Developing CCS in 2030 can put California on path to meet its 2045 goals effectively




## No CCS



## CCS





## Key Takeaways

---

- **SB100 Pathways Project (Long et al. 2020, *in review*)**
  - Reaching a net zero carbon grid in 2045 in California can be done cost-effectively if we develop ~30 GW of Clean Firm Resources
- **An Action Plan for Carbon Capture and Storage in California: Opportunities, Challenges, and Solutions (EFI and Stanford University, 2020)**
  - Utilizing NGCC-CCS in the electricity grid as early as 2030 to meet emissions reductions goals is cost-effective and puts California on path to meet its 2045 goals



Thank you for listening!  
I'd be happy to take  
Questions:  
[@ebaik@stanford.edu](mailto:@ebaik@stanford.edu)

**FIGURE 3-6**  
**CAPACITY OF CALIFORNIA'S ELECTRICITY**  
**SYSTEM IN 2030 WITH AND WITHOUT CCS**

